

The following information is provided for the month of January, 2015

Pertinent Process Information

Sample		Plant Limit	Plant Actual Result	units
BOD		5 Max	0.1	mg/l
NH3		1 Max	0.25	mg/l
TSS		30 Max	0.7	mg/l
Avg.Flow		3.15 Max	1.146	MGD
Min. Flow		N/A	0.86	MGD
Max. Flow		N/A	2.79	MGD

Sample	Incoming Waters (mg/l)	Outgoing Waters (mg/l)	% of Pollutant Removed
BOD	201	0.1	100.0%
NH3	20.6	0.25	98.8%
TSS	398	0.7	99.8%

Average Oxidation Ditch Solids Concentration

mg/l*

Gallons of Water Treated

MG*

Gallons Of Sludge Wasted to digesters

MG*

Is The WWTP Compliant For This Month?

Yes

- * BOD= Biological Oxygen Demand
- * NH3 = Ammonia
- * TSS = Total Suspended Solids
- mg/l = milligrams per liter
- MG = Million Gallons
- MGD = Million Gallons Per day

