

The following information is provided for the month of **October**, 2014

Pertinent Process Information

Sample		Plant Limit	Plant Actual Result	Units
BOD		5 Max	0	mg/l
NH3		1 Max	0.71	mg/l
TSS		30 Max	0	mg/l
Avg. Flow		3.15 Max	1.146	MGD
Min. Flow		N/A	0.71	MGD
Max. Flow		N/A	3.88	MGD

Sample	Incoming Waters (mg/l)	Outgoing Waters (mg/l)	% of Pollutant Removed	
BOD	200	0	100.0%	
NH3	22.9	0.71	96.9%	
TSS	375	0	100.0%	

Average Oxidation Ditch Solids Concentration

mg/l*

Gallons of Water Treated

MG*

Gallons Of Sludge Wasted to digesters

MG*

Is The WWTP Compliant For This Month?

Yes

- * BOD= Biological Oxygen Demand
- * NH3 = Ammonia
- * TSS = Total Suspended Solids
- mg/l = milligrams per liter
- MG = Million Gallons
- MGD = Million Gallons Per day