



Parameter	Incoming Waters Pollutant Levels	Units
BOD	306	Milligrams Per Liter
Ammonia	17	Milligrams Per Liter
Total Suspended Solids	288	Milligrams Per Liter
Total Volume Treated	40.42	Million Gallons

Parameter	Permit Limit Monthly Avg.	Discharge Waters Pollutant Levels	Units
BOD	5.0 Summer/ 10 Winter	.263	Milligrams Per Liter
Ammonia	1.0 Summer/ 2.0 Winter	0	Milligrams Per Liter
Total Suspended Solids	30	0	Milligrams Per Liter
Average Flow	3.5	1.303	Million gallons per day
Minimum Daily Flow	None	.68	Million gallons per day
Maximum Daily Flow	None	7.7	Million gallons per day
Percentage of Biological Oxygen Demand removed from discharge waters		99.9 %	
Percentage of Ammonia Nitrogen removed from discharge waters		100 %	
Percentage of Total Suspended Solids removed from discharge waters		100 %	

Nutrient Monthly Average Discharge Levels

Total Nitrogen	6.56 mg/l
Total Phosphorus	.476 mg/l

✓ The City of Oxford WWTP was compliant for the month and year stated above.

The City of Oxford WWTP was not compliant for the month and year stated above.

❖ BOD – Biological Oxygen Demand