

The following information is provided for the month of July, 2014

Pertinent Process Information

| Sample | | Plant Limit | Plant Actual Result | units |
|-----------|--|-------------|---------------------|-------|
| BOD | | 5 Max | 0.7 | mg/l |
| NH3 | | 1 Max | 0.05 | mg/l |
| TSS | | 30 Max | 0.1 | mg/l |
| Avg.Flow | | 3.15 Max | 0.95 | MGD |
| Min. Flow | | N/A | 0.67 | MGD |
| Max. Flow | | N/A | 1.49 | MGD |

| Sample | Incoming Waters (mg/l) | Outgoing Waters (mg/l) | % of Pollutant Removed | |
|--------|------------------------|------------------------|------------------------|--|
| BOD | 278 | 1.8 | 99.4% | |
| NH3 | 18.4 | 0.01 | 99.9% | |
| TSS | 431 | 1.9 | 99.6% | |

Average Oxidation Ditch Solids Concentration

mg/l*

Gallons of Water Treated

MG*

Gallons Of Sludge Wasted to digesters

MG*

Is The WWTP Compliant For This Month?

Yes

- * BOD= Biological Oxygen Demand
- * NH3 = Ammonia
- * TSS = Total Suspended Solids
- mg/l = milligrams per liter
- MG = Million Gallons
- MGD = Million Gallons Per day