



Parameter	Incoming Waters Pollutant Levels	Units
BOD	314	Milligrams Per Liter
Ammonia	12.2	Milligrams Per Liter
Total Suspended Solids	497	Milligrams Per Liter
Total Volume Treated	28.15	Million Gallons

Parameter	Permit Limit Monthly Avg.	Discharge Waters Pollutant Levels	Units
BOD	5.0 Summer/ 10 Winter	1.85	Milligrams Per Liter
Ammonia	1.0 Summer/ 2.0 Winter	.04	Milligrams Per Liter
Total Suspended Solids	30	5.4	Milligrams Per Liter
Average Flow	3.5	.918	Million gallons per day
Minimum Daily Flow	None	.700	Million gallons per day
Maximum Daily Flow	None	1.45	Million gallons per day
Percentage of Biological Oxygen Demand removed from discharge waters		99.4 %	
Percentage of Ammonia Nitrogen removed from discharge waters		99.6 %	
Percentage of Total Suspended Solids removed from discharge waters		98.9 %	

Nutrient Monthly Average Discharge Levels

Total Nitrogen	7.95 mg/l
Total Phosphorus	.0915 mg/l

✓ The City of Oxford WWTP was compliant for the month and year stated above.

The City of Oxford WWTP was not compliant for the month and year stated above.

❖ BOD – Biological Oxygen Demand