

The following information is provided for the month of February, 2015

### Pertinent Process Information

Sample		Plant Limit	Sample Result	units
BOD		5 Max	1.1	mg/l
NH3		1 Max	0	mg/l
TSS		30 Max	2.9	mg/l
Avg. Flow		3.15 Max	1.305	MGD
Min. Flow		N/A	0.9	MGD
Max. Flow		N/A	2.29	MGD

Parameter	Incoming Waters (mg/l)	Outgoing Waters (mg/l)	% of Pollutant Removed
BOD	155	1.1	99.3%
NH3	18.8	0	100.0%
TSS	337	2.9	99.1%

**Average  
Oxidation  
Ditch Solids  
Concentration**

2569 mg/l\*

**Gallons of Water Treated**

36.90 MG\*

**Gallons Of Sludge Wasted to digesters**

0.4 MG\*

**Is The WWTP Compliant For This Month?**

Yes

- \* BOD= Biological Oxygen Demand
- \* NH3 = Ammonia
- \* TSS = Total Suspended Solids
- mg/l = milligrams per liter
- MG = Million Gallons
- MGD = Million Gallons Per day