

The following information is provided for the month of March, 2015

**Pertinent Process Information**

Sample		Plant Limit	Plant Actual Result	units
BOD		5 Max	4.1	mg/l
NH3		1 Max	0.08	mg/l
TSS		30 Max	5.87	mg/l
Avg. Flow		3.15 Max	1.745	MGD
Min. Flow		N/A	0.99	MGD
Max. Flow		N/A	4.07	MGD

Parameter	Incoming Waters (mg/l)	Outgoing Waters (mg/l)	% of Pollutant Removed
BOD	179	4.1	97.7%
NH3	19.4	0.08	99.6%
TSS	361	5.87	98.4%

**Average Oxidation Ditch Solids Concentration**

mg/l\*

**Gallons of Water Treated**

MG\*

**Gallons Of Sludge Wasted to digesters**

MG\*

**Is The WWTP Compliant For This Month?**

Yes

- \* BOD= Biological Oxygen Demand
- \* NH3 = Ammonia
- \* TSS = Total Suspended Solids
- mg/l = milligrams per liter
- MG = Million Gallons
- MGD = Million Gallons Per day